

Firmware:

Web-IO Digital 24xIn, 24xOut 19" OEM

Model 57632

Current firmware

Date	Changes and comments	Revision
February 21, 2014	<ul style="list-style-type: none">• Number of network buffers for UDP increased• SNMP: Setting of the alarm triggers optimized• Basic initializing on bootup optimized• Optimizing of firmware upload in noisy environments• Boot-up behavior optimized• Box-to-Box - address management for NAT routing adjusted• Login for binary access revised• UDP - network buffer expanded• UDP - remote port can be set as desired• Negative logic for outputs configurable• State=TOGGLE introduced for socket command outputaces• DHCP: Device Name = DHCP Name <p>To load this firmware, WuTility must be used in the newest version included!</p>	2.32 ZIP download

[Show older firmware...](#)



We are available to you in person:

Wiesemann & Theis
GmbH
Porschestr. 12
42279 Wuppertal
Phone: +49 202/2680-110 (Mon.-Fri. 8 a.m. to 5 p.m.)
Fax: +49 202/2680-265
info@wut.de

© Wiesemann & Theis GmbH, subject to mistakes and changes: Since we can make mistakes, none of our statements should be applied without verification. Please let us know of any errors or misunderstandings you find so that we can become aware of and eliminate them.

[Data Privacy](#)