

Firmware:

# Web-IO 4.0 230V Relay 1xNO, 1xCO

Model 57832

## Current firmware

Date	Changes and comments	Revision
April 5, 2022	<ul style="list-style-type: none"><li>• Passwords - non-allowed characters are rejected</li><li>• Firmware update: Initiating via button in the interface possible</li><li>• Emergency access - missing login page added</li><li>• SNMP - MIBs and OIDs expanded</li><li>• OPC UA - Node-IDs can be modified via list upload</li><li>• Actions - switching of multiple outputs optimized</li></ul> <p>Please use the newest included version of Wutility for the update.</p>	1.56 <a href="#">ZIP download</a>

[Show older firmware...](#)



### We are available to you in person:

Wiesemann & Theis  
GmbH  
Porschestra. 12  
42279 Wuppertal  
Phone: +49 202/2680-110 (Mon.-Fri. 8 a.m. to 5 p.m.)  
Fax: +49 202/2680-265  
info@wut.de

© Wiesemann & Theis GmbH, subject to mistakes and changes: Since we can make mistakes, none of our statements should be applied without verification. Please let us know of any errors or misunderstandings you find so that we can become aware of and eliminate them.

[Data Privacy](#)